

## GENERAL NOTES:

1. CONNECT ALL CIRCUITS TO PANEL B1R3A UNLESS NOTED OTHERWISE.
2. REFER TO DRAWING E2.10.44 AND E2.10.45 FOR 480VAC MECHANICAL EQUIPMENT FEEDER SIZES, UNLESS NOTED OTHERWISE.
3. MOTORS ARE PROVIDED WITH MECHANICAL EQUIPMENT AND SHOWN FOR CLARITY ONLY.

## KEYNOTES:

- N001 SEE DRAWING E8.10.40 FOR ENLARGED PLAN OF THE ELECTRICAL ROOM.
- N002 CONNECT ALL CIRCUITS TO PANEL B1R3A UNLESS NOTED OTHERWISE.
- N003 CONNECT 480VAC, 3PH, 30A FEEDER AND DISCONNECT SWITCH FOR TRASH COMPACTOR CONTROL TO PANEL B1DPPB. (TYP. 1)
- N004 CONNECT 480VAC, 3PH, 30A FEEDER AND DISCONNECT SWITCH FOR MOTORIZED OVERHEAD DOOR CONTROL TO PANEL B1DPPB. (TYP. 6)
- N005 CONNECT 480VAC, 3PH, 30A FEEDER AND DISCONNECT SWITCH FOR TRUCK DOCK LEVELER CONTROL TO PANEL B1DPPB. (TYP. 3)
- N006 CONNECT 120VAC, 1PH, 20A CIRCUIT FOR TRUCK RESTRAINT CONTROL TO PANEL B1R4A. (TYP. 3)
- N007 CONNECT 480VAC, 3PH, 30A FEEDER AND DISCONNECT SWITCH FOR MOTORIZED OVERHEAD DOOR CONTROL TO PANEL B1DPPB. (TYP. 2)
- N008 CONNECT ALL CIRCUITS FOR FAN COIL UNITS FCU-CL-006,007,008 AND UNIT HEATERS UH-CL-1,2 AND 3 TO PANEL B1R3A.
- N009 CONNECT ALL CIRCUITS FOR FAN COIL UNITS FCU-CL-002,003,004,005 AND 007 TO PANEL B1R4A.
- N010 CONNECT 480VAC, 3PH, 100A FEEDER AND DISCONNECT SWITCH FOR ELEVATOR EQUIPMENT CONTROL TO B1DPPB.
- N011 CONNECT 120VAC, 1PH, 20A CIRCUIT FOR ELEVATOR CAB LIGHTING AND CONTROL TO PANEL TEA.
- N012 PROVIDE INCANDESCENT LIGHT FOR ELEVATOR PIT, CROUSE-HINDS FORM 200 CAT No. V022009 OR APPROVED EQUAL.
- N013 CONNECT HOT WATER CARNET UNIT CH-CL-004 TO PANEL B1R3A AND CH-CL-003 TO B1R1A.
- N014 NOT USED
- N015 CONNECT 120VAC, 1PH, 20A CIRCUIT FOR UV LAMP SERVICE TO PANEL B1R1A.
- N016 MOTORIZED OVERHEAD DOOR CONTROL IS MOUNTED AND WIRED BY DOOR VENDOR. PROVIDE CONDUIT ONLY. (TYP)
- N017 CONNECT 120VAC, 1PH, 20A CIRCUIT FOR EXHAUST FAN EF-CL-11 AND 15 TO PANEL B1R4A.

